



## HYDROGEOLOGIC DATABASE Chemical Analysis

[Click HERE to View Information for Well GPQ](#)

### Sample Results Color Code Legend

Sample Exceeds None Secondary Primary MCL



Owner Name: **Don Ferris**

Well Key: **GPQ**

Site Type: **Well**

TRS: **32N/03E-20N**

PWS Name: **Terrys Corner Water System**

DOH PwsID: **AA395**

DOH Source #: **1**

		Bicarbonate				Conductivity		Hardness				Turbidity					
Source	Date	Alk	As		Ca	Cl		Fe		K	Mg	Mn	Na	NO3	SO4		TDS
DOH	4/10/2002		< 0.002			23	547	< 0.1	237			0.602	16	< 0.5	39	0.4	

### Select Summary Statistics

Avg As:	0.001	Avg Cl:	23.0	Avg Hardness:	237	Avg NO3:	0.25
Median As:	0.001	Median Cl:	23.0	Median Hardness:	237	Median NO3:	0.25
Max As:	0.001	Max Cl:	23.0	Max Hardness:	237	Max NO3:	0.25

Bacteria Samples (distribution): [2 sample\(s\)](#)

Disclaimer: Data presented has been collected from a variety of sources. Island County makes no guarantee as to the validity or accuracy of this data.  
Please report any errors to the Island County Hydrogeologist.

Generated by the Island County Hydrogeologic Database

1 records printed on 9/17/2019

Note: Items with [blue frames and blue text](#) are clickable hyperlinks to additional information / resources.

Parameter labels with a [red fill color](#) are exhibiting an increasing trend, and those with a [green fill color](#) are exhibiting a decreasing trend.